

SUDAS Revision Submittal Form

Status Date: As of 5/20/2020 **Topic:** Steps in deep structures
Manual: Specifications **Manual Location:** Section 6010, 2.13; Figures SW-301
303, 304, 305, 401, 404, and 405

Requested Revision:

2.13 STEPS

~~A. Do not install steps in manholes or intakes unless otherwise specified in the contract documents.~~

A. Depths:

1. For manholes and intakes less than 20 feet deep, do not install steps unless otherwise specified in the contract documents.

2. For manholes and intakes deeper than 20 feet, install steps to meet OSHA regulations.

~~B. If specified, comply with the following~~ **Requirements:**

1. ASTM C 478.
2. Manufacture using polypropylene encased steel.
3. Uniformly space steps at 12 to 16 inches.
4. Align with vertical side of eccentric top section.
5. Place first step no more than 36 inches from top of casting.

Reason for Revision: Added steps for structures deeper than 20 feet.

Comments: None.

District: 1 2 3 4 5 6 **2/27/2020 Webinar**

Comments: None.

District: 1 2 3 4 5 6 **4/2020 Webinars**

Comments: None.

Action: Deferred Not Approved Approved

Final District Action Summary: All 6 districts approved.

Board of Directors Action: Approved.