

SUDAS Revision Submittal Form

Status Date: As of 5/20/2020 **Topic:** Visual inspection of sewers
Manual: Specifications **Manual Location:** Section 4060, 3.02

Requested Revision:

~~3.02 — VISUAL INSPECTION~~

- ~~A. Check each section of sanitary sewer, storm sewer, or pipe culvert by lamping.~~
- ~~B. Light should be visible through section of pipe lamped.~~
- ~~C. Visually inspect each run of pipe.~~
- ~~D. Repair or replace defective pipe or joints, or remove and relay pipe not meeting alignment tolerances, as directed by the Engineer.~~

Reason for Revision: Lamping is a method no longer used.

Comments: 3.03 = Video Inspection, 3.04 = Sanitary Sewer Leakage Testing, 3.05 = Deflection Testing, 3.06 = Force Main Testing. All will be renumbered if 3.02 is deleted.

District: 1 2 3 4 5 6 **2/27/2020 Webinar**
Comments: None.

District: 1 2 3 4 5 6 **4/2020 Webinars**
Comments: None.

Action: Deferred Not Approved Approved

Final District Action Summary: All 6 districts approved.

Board of Directors Action: Approved.