

SUDAS Revision Submittal Form

Status Date: As of 5/18/2022 **Topic:** Cement alternatives
Manual: Specifications **Manual Location:** Section 7010, 2.01, A

Requested Revision:

2.01 MATERIALS

- A. Cement:** Meet the requirements of Iowa DOT Section 4101 and Materials I.M. 401, including Type I and Type II cements and blended hydraulic cements Type 1P, Type 1S, Type 1T, and Type 1L.

Reason for Revision: Added Type 1T cement as an option for Type I/II cements; 1T is a ternary blend with slag/limestone or pozzolan/limestone.

Comments: None.

District: 1 2 3 4 5 6

Comments: None.

Action: Deferred Not Approved Approved

Final District Action Summary: All 6 districts approved.

Board of Directors Action: Approved.