

SUDAS Revision Submittal Form

Status Date: As of 11/7/2022 **Topic:** Dowel bars for PCC patches
Manual: Specifications **Manual Location:** Section 7040, 2.01, F

Requested Revision:

2.01 MATERIALS

F. Tie Bars and Dowel Bars: Provide epoxy coated bars complying with Iowa DOT Section 4151 or glass fiber reinforced polymer bars complying with Iowa DOT Section 4156.

Reason for Revision: Added glass fiber reinforced polymer bars for use in full depth PCC patches.

Comments: None.

District: 1 2 3 4 5 6

Comments: None.

Action: Deferred Not Approved Approved

Final District Action Summary: All 6 districts approved.

Board of Directors Action: Approved.