

SUDAS Revision Submittal Form

Status Date: As of 11/7/2022 **Topic:** PCC mix for SW, DW, and SUP
Manual: Specifications **Manual Location:** Section 7030, 2.01

Requested Revision:

PART 2 - PRODUCTS

2.01 PORTLAND CEMENT CONCRETE

- A. Use Class ~~B~~ **A** or C concrete **for sidewalks and driveways** and Class C **for shared use paths** with materials complying with [Section 7010](#). Use coarse aggregate of Class 2 durability or better.
- B. Comply with the following for PCC mixes for sidewalks, shared use paths, and driveways unless otherwise approved by the Engineer.

Table 7030.01: PCC Mixes

	Machine Finish	Hand Finish
Type of Concrete	Class B A or C	Class B A or C
Slump Minimum	1/2 in.	1/2 in.
Slump Maximum	2 1/2 in.	4 in.
Percent Air Content		
• Target	7%	7%
• Minimum	6%	6%
• Maximum	8 1/2%	8 1/2%

Reason for Revision: Deleted Class B mixes due to high water/cement ratio. Added A mix as an option for sidewalks and driveways.

Comments: None.

District: 1 2 3 4 5 6

Comments: None.

Action: Deferred Not Approved Approved

Final District Action Summary: All 6 districts approved.

Board of Directors Action: Approved.